

Handled by, department
Ingvar Sahlin
 Certification
 +46 10 516 56 67, ingvar.sahlin@sp.se

Westcoast Windows AB
 Kardanvägen 42
 SE461 38 TROLLHÄTTAN
 Sweden

Summary Initial Type- Testing Report for EC Declaration of Conformity

SP Technical Research Institute of Sweden has as Notified Body no. 0402, performed Initial Type-Testing of the products mentioned below according to the requirements in the harmonized standard **EN 14351-1:2006** Windows and doors – Product standard, performance characteristics. This report may be used as support for an EC Declaration of Conformity in accordance with the Construction Products Directive CPD, 89/106/EEC.

Product name and description

Westcoast Windows vertical single/double sliding sash(es) opening outwards.

Product and description	Evaluation of conformity according to EN 14351, table ZA.3b	Declared value, class or similar	Test report / Assessment
SSG 90 Vertical sliding 3-glass	4:2 Resistance to wind load - Test pressure (Pa) Frame deflexion	Class 3 (600) C (<1/300)	SP P-marking list dated 2007-04-03
	4:5 Water-tightness - Test pressure (Pa)	Class 8A (600)	
	4:12 Thermal transmittance U_w ($W/m^2 \cdot K$) SSG 90, 100-31	Npd	
	4:14 Air permeability - Test pressure (Pa)	Class 4 (600)	SP P-marking list dated 2007-04-03
SSG 90-2 Vertical sliding 2-glass	4:2 Resistance to wind load - Test pressure (Pa) Frame deflexion	Class 3 (600) C (<1/300)	SP P-marking list dated 2007-04-03
	4:5 Water-tightness - Test pressure (Pa)	Class 8A (600)	
	4:12 Thermal transmittance U_w ($W/m^2 \cdot K$)	Npd	
	4:14 Air permeability - Test pressure (Pa)	Class 4 (600)	SP P-marking list dated 2007-04-03

Npd = No performance determined.

SP Technical Research Institute of Sweden Certification


Lennart Månsson
 Certification Manager


Ingvar Sahlin
 Certification Officer

SP Technical Research Institute of Sweden

<i>Postal address</i>	<i>Office location</i>	<i>Phone / Fax / E-mail</i>
SP Box 857 SE-501 15 Borås SWEDEN	Västeråsen Brinellgatan 4 SE-504 62 Borås SWEDEN	+46 10 516 50 00 +46 33 13 55 02 info@sp.se

Swedish Notified Bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of SP.